

BNPM/LTE/AFES /760/2018-19	BANK NOTE PAPER MILL INDIA PRIVATE LIMITED	Cover Sheet
	CORRIGENDUM NO. 1 Supply of Compressed Air System Filters (3 Types) at BNPM Plant, Mysuru	Sheet 1 of 3

CORRIGENDUM NO. 1 DATED 08.01.2019

FOR

TENDER No.

BNPM/LTE/AFES/760/2018-19 DATED 18.12.2018

FOR

Supply of Compressed Air System Filters (3 Types) at BNPM Plant, Mysuru

PURCHASER : BANK NOTE PAPER MILL INDIA PRIVATE LIMITED

EQUIPMENT : COMPRESSED AIR SYSTEM

LOCATION : BNPM PLANT, MYSURU, KARNATAKA



**ISSUE
R1**

BNPM/LTE/AFES /760/2018-19	BANK NOTE PAPER MILL INDIA PRIVATE LIMITED	Cover Sheet
	CORRIGENDUM NO. 1 Supply of Compressed Air System Filters (3 types) at BNPM Plant, Mysuru	Sheet 2 of 3

1.0 SCOPE OF THIS CORRIGENDUM

1. Details provided in this corrigendum shall override those mentioned in the tender no. BNPM/LTE/AFES/760/2018-19 Dated: 18.12.2018

2. Except for details mentioned herein, all other details contained in the tender no. BNPM/LTE/AFES/760/2018-19 Dated: 18.12.2018 shall remain unchanged.

3. Due date of bid submission:

Closing date and time for receipt of tenders	22.01.2019; 1600 Hrs.
Time and date of opening of techno-commercial bid	22.01.2019; 1630 Hrs.

4. Clarification to bidders' queries:

Sl. No.	Bidders Queries	Action/Clarification incorporated in this Corrigendum
1.	Detailed drawings of tendered filters required	<p>Detailed drawings are not available at the present, prospective bidders may design the filters to meet the technical specifications indicated in the tender.</p> <p>It may be noted that filter design shall take care of the flow, pressure, micron ratings and other details of the filters as envisaged in the tender. Overall size and weight of the filters indicated in the tender specification are for indicative purposes only, however bidder shall take care to design the filters as compact as possible for ease of installation and maintenance</p> <p>Successful bidder shall submit the detailed drawings of the filters for BNPM approval prior to taking up manufacturing the filters.</p>



BNPM/LTE/AFES /760/2018-19	BANK NOTE PAPER MILL INDIA PRIVATE LIMITED	Cover Sheet
	CORRIGENDUM NO. 1 Supply of Compressed Air System Filters (3 types) at BNPM Plant, Mysuru	Sheet 3 of 3

2.	<p><u>Performance of the filter: (To be read along with Section VII: Technical Specifications)</u></p> <p>a) Factory performance test certificate to be submitted by the successful bidder providing the efficiency and the performance of the filters as indicated in the technical specifications.</p> <p>b) Factory performance test shall be conducted in the presence of BNPM officials only</p> <p>c) Further during the warranty period of 12 months, BNPM may get the air quality checked by an external lab/reputed agency the performance of the filters and if the performance of the filters does not meet the requirement mentioned in the technical specifications provided in the tender, successful bidder has to replace the material which shall meet the tender specification free of cost.</p> <p>Minimum Air quality at the outlet of the filters shall be as follows which needs to be proved during factory performance test by the successful bidder.</p> <p><u>Quality of the Air at Pre Filter Outlet</u></p> <p>i) Max. Oil Content: 1mg/m³</p> <p>ii) Max. particle size: 3µm</p> <p><u>Quality of the Air at Fine Filter Outlet</u></p> <p>i) Max. Oil Content: 0.01mg/m³</p> <p>ii) Max. particle size: 2µm</p> <p><u>Quality of the Air at Carbon Filter Outlet</u></p> <p>i) Max. Oil Content: 0.003mg/m³</p>
----	---

