	BANK NOTE PAPER MILL INDIA PRIVATE LIMITED	Cover Sheet
BNPM/NCB/MCCP/1123	CORRIGENDUM No. 4	
/ 2019-20	Design, Manufacture, Supply, Installation, Testing & Commissioning of MCC Panels at BNPM Plant, Mysuru	Sheet 1 of 3

CORRIGENDUM NO. 4 DATED 30.04.2020

FOR

TENDER No. BNPM/NCB/MCCP/1123/2019-20 DATED 21.02.2020

FOR

Design, Manufacture, Supply, Installation, Testing & Commissioning of MCC Panels at BNPM Plant, Mysuru

PURCHASER : BANK NOTE PAPER MILL INDIA PRIVATE LIMITED

MATERIAL : MCC PANELS

LOCATION : BNPM PLANT, MYSURU, KARNATAKA



DNDM (NCD /MCCD /4422	BANK NOTE PAPER MILL INDIA PRIVATE LIMITED	Cover Sheet
BNPM/NCB/MCCP/1123 / 2019-20	CORRIGENDUM No. 4	
	Design, Manufacture, Supply, Installation, Testing & Commissioning of MCC Panels at BNPM Plant, Mysuru	Sheet 2 of 3

1.0 SCOPE OF THIS CORRIGENDUM

- 1. Details provided in this corrigendum shall override those mentioned in the tender no. BNPM/NCB/MCCP/1123/2019-20 Dated: 21.02.2020
- 2. Except for details mentioned herein, all other details contained in the tender no. BNPM/NCB/MCCP/1123/2019-20 Dated: 21.02.2020 shall remain unchanged.

3. Due date of bid submission:

Closing date and time for receipt of tenders	15.05.2020; 1430 Hrs.	
Time and date of opening of techno-commercial bid	15.05.2020; 1500 Hrs.	

4. Inclusions/Clarifications through this corrigendum:

Sl. No.	As per Tender Clause	Action/Clarification incorporated in this Corrigendum
	Section VII - Technical Specifications: {Page no. 33 of 70} 4. Core Cutting:	
1	Bidder Queries: (a) Core cutting: No. of cutting and thickness of slab is to be identified	(a) No. of core cutting shall be as per the no. of cable entry / exit points in the bottom entry panels. Thickness of Slab: Approx. 300 mm RCC floor with epoxy flooring
2	Section VII - Technical Specifications: {Page no. 33 of 70} 5. Sealing of floor openings & Scaffolding: Bidder Queries: (b) Scaffolding building height is required	(b) Approx. 10m (Bidders shall visit BNPM site to understand the exact volume of work before participation in the tender)
3	Section VII - Technical Specifications: {Page no. 41,42 & 43 of 70} 11,12 & 13: Schematic Diagram for Panels Bidder Queries: (c) SLD for panel is required	(c) Panels specified in tender is Power Distribution Panels only Also, As per Clause 7 of Section VII: Technical Specifications, Drawings & BOM should be submitted by the bidders.



DNDM (NCD /MCCD /4422	BANK NOTE PAPER MILL INDIA PRIVATE LIMITED	Cover Sheet
BNPM/NCB/MCCP/1123 / 2019-20	CORRIGENDUM No. 4	
	Design, Manufacture, Supply, Installation, Testing & Commissioning of MCC Panels at BNPM Plant, Mysuru	Sheet 3 of 3

Sl. No.	As per Tender Clause	Action/Clarification incorporated in this Corrigendum
4	Bidder Queries: (d) As per SIT, we are eligible for exemption for payment of EMD.	(d) Conditions for claiming exemption from payment of EMD: EMD is exempted for Micro and Small enterprises (MSEs) as per the Public Procurement Policy for MSEs Order, 2012. MSEs should be registered and also will continue to remain registered during the tender validity period with District Industries Centre (DIC) or Khadi and Village Industries Commission (KVIC) or Khadi and Industries Board (KVIB) or Coir Board or National Small Industries Corporation (NSIC) or Directorate of Handicrafts and Handlooms or Udyog Aadhaar Memorandum or Any other body specified by Ministry of MSME).

