

BNPM/NCB/323/2025 -26 dated 29.10.2025	BANK NOTE PAPER MILL INDIA PRIVATE LIMITED	SHEET 1 OF 8
	TENDER FOR SUPPLY, INSTALLATION, TESTING, COMMISSIONING OF DYNAMIC VOLTAGE SAG CORRECTOR AT BNPM PLANT, MYSURU. CORRIGENDUM NO. 1	

CORRIGENDUM No. 1, DATED 19.11.2025

FOR

TENDER NO. BNPM/NCB/323/2025-26 dated 29.10.2025

**TENDER FOR SUPPLY, INSTALLATION, TESTING, COMMISSIONING OF
DYNAMIC VOLTAGE SAG CORRECTOR AT BNPM PLANT, MYSURU.**



BNPM/NCB/323/2025 -26 dated 29.10.2025	BANK NOTE PAPER MILL INDIA PRIVATE LIMITED	SHEET 2 OF 8
	TENDER FOR SUPPLY, INSTALLATION, TESTING, COMMISSIONING OF DYNAMIC VOLTAGE SAG CORRECTOR AT BNPM PLANT, MYSURU. CORRIGENDUM NO. 1	

1.0 SCOPE OF THIS CORRIGENDUM

- 1.1 This corrigendum dated 19.11.2025 is issued for clarification, addition, amendment and extension of bid submission due date and amendment to tender terms.
- 1.2 Except for details mentioned herein, all other details contained in the tender no. BNPM/NCB/323/2025-26 dated 29.10.2025, shall remain applicable and unchanged.

2.0 CLARIFICATION TO THE TENDER:

<u>Sl. No.</u>	<u>Tender Clause</u>	<u>Pre-bid query</u>	<u>Action/Clarification</u>
1	Sec VII, Technical Specification & Scope of Work, Clause 2 and 3	Software and Laptop Supply PME software and laptop required for monitoring and configuration shall be included in the vendor's scope of supply. Kindly confirm.	Yes. Under the scope of bidder.
2	Sec IX, Experience & Past Performance: Qualification/Eligibility Criteria	PQR (Pre-Qualification Requirement) The OEM will issue an authorization letter to the bidder. The bidder shall submit the OEM's PQR documents to qualify. Global supplies from the OEM are also acceptable. Kindly confirm acceptance.	As per tender terms. Global supplies from the OEM are acceptable.



BNPM/NCB/323/2025 -26 dated 29.10.2025	BANK NOTE PAPER MILL INDIA PRIVATE LIMITED	SHEET 3 OF 8
	TENDER FOR SUPPLY, INSTALLATION, TESTING, COMMISSIONING OF DYNAMIC VOLTAGE SAG CORRECTOR AT BNPM PLANT, MYSURU. CORRIGENDUM NO. 1	

<u>Sl. No.</u>	<u>Tender Clause</u>	<u>Pre-bid query</u>	<u>Action/Clarification</u>
3	Sec IX, Experience & Past Performance: Qualification/Eligibility Criteria	OEM reference to be accepted.	Refer aforementioned Sr No. 2.
4	Sec VII, Technical Specification & Scope of Work: Detailed Scope of Work, Clause 3.10	Required 2 days shutdown per DySC system with site readiness & Shutdown to be given within 4 weeks against Supply.	Suitable contract period extension without any price escalation may be provided for any delay pertaining to BNPM, this is to be read along with Sec IV: GCC: Clause 23: Delay in the supplier's performance.
5	Sec IV: GCC, Clause 9, Sec V: SCC, Sl. No. 3: Inspection and Quality Control	Factory Location & Inspection: The Schneider make Voltage Sag Correctors are manufactured at the Spain factory. In case of a physical inspection, visa, travel, and accommodation shall be in the customer's scope. Alternatively, a	BNPM reserves the right to carry out physical inspection at successful bidder's works or virtual inspection or waive-off inspection. In case of physical



BNPM/NCB/323/2025 -26 dated 29.10.2025	BANK NOTE PAPER MILL INDIA PRIVATE LIMITED	SHEET 4 OF 8
	TENDER FOR SUPPLY, INSTALLATION, TESTING, COMMISSIONING OF DYNAMIC VOLTAGE SAG CORRECTOR AT BNPM PLANT, MYSURU. CORRIGENDUM NO. 1	

<u>Sl. No.</u>	<u>Tender Clause</u>	<u>Pre-bid query</u>	<u>Action/Clarification</u>
		virtual inspection can be arranged. Please confirm the preferred mode.	inspection, all travel related expenses for BNPM officer/(s) are in scope of BNPM.

3.0 AMENDMENT TO THE TENDER:

<u>Sl. No.</u>	<u>Tender Clause</u>	<u>Pre-bid query</u>	<u>Existing tender terms</u>	<u>Amendment to the tender terms</u>
1	Sec VI: LOR: Completi on period:	Project Timeline Since this is a shutdown-related activity, we kindly request an extension of the project delivery timeline from 4 months to 5 months.	The entire work as per the scope of work including supply, installation, commissioning are to be completed within 4 months from the date of issuance of order/LOI (whichever is earlier).	The entire work as per the scope of work including supply, installation, commissioning are to be completed within 5 months from the date of issuance of order/LOI (whichever is earlier).



BNPM/NCB/323/2025 -26 dated 29.10.2025		BANK NOTE PAPER MILL INDIA PRIVATE LIMITED		SHEET 5 OF 8
		TENDER FOR SUPPLY, INSTALLATION, TESTING, COMMISSIONING OF DYNAMIC VOLTAGE SAG CORRECTOR AT BNPM PLANT, MYSURU. CORRIGENDUM NO. 1		
Sl. No.	Tender Clause	Pre-bid query	Existing tender terms	Amendment to the tender terms
2	SCC, Sec V: SCC, Clause 13: Terms & Mode of Payment:	As the scope involves both supply and erection, testing & commissioning activities, and considering our dependency on BNPM's shutdown schedule, we request that at least 60% payment be processed within 30 days from the date of supply.	A. Main product: a. 100% of the order value excluding the value for laying 3C x 240 Sq.mm Cu Armoured Cable shall be released within 30 days after completion of supply, installation, commissioning as per scope of work and on submission of invoice. b. Payment for laying 3C x 240 Sq.mm Cu Armoured Cable shall be released within 30 days after completion of supply, installation, commissioning as per scope of work, on submission of invoice and based on actual measurement basis and as per the quoted unit rates. B. Essential Spares: It is the discretion of BNPM to issue order for essential spares within the price validity period as mentioned in SCC, Sec V, Clause 14: Contract price. If essential spares are ordered then	A. Main product: a. 60% of the order value excluding the value for laying 3C x 240 Sq.mm Cu Armoured Cable shall be released within 30 days after receipt and acceptance of supply at BNPM, Mysore and on submission of invoice. b. 40% of the order value excluding the value for laying 3C x 240 Sq.mm Cu Armoured Cable shall be released within 30 days after completion of installation, commissioning as per scope of work and on submission of invoice. B. Cable: Payment for laying 3C x 240 Sq.mm Cu Armoured Cable shall be released within 30 days after completion of supply, installation, commissioning as per scope of work, on submission of



BNPM/NCB/323/2025 -26 dated 29.10.2025		BANK NOTE PAPER MILL INDIA PRIVATE LIMITED			SHEET 6 OF 8
		TENDER FOR SUPPLY, INSTALLATION, TESTING, COMMISSIONING OF DYNAMIC VOLTAGE SAG CORRECTOR AT BNPM PLANT, MYSURU. CORRIGENDUM NO. 1			
<u>Sl. No.</u>	<u>Tender Clause</u>	<u>Pre-bid query</u>	<u>Existing tender terms</u>	<u>Amendment to the tender terms</u>	
			100% of the order value shall be released within 30 days after receipt and acceptance of supply and on submission of invoice. Payment shall be released in INR and vide electronic mode only.	invoice and based on actual measurement basis and as per the quoted unit rates. C. Essential Spares: It is the discretion of BNPM to issue order for essential spares within the price validity period as mentioned in SCC, Sec V, Clause 14: Contract price. If essential spares are ordered then 100% of the order value shall be released within 30 days after receipt and acceptance of supply and on submission of invoice. Payment shall be released in INR and vide electronic mode only.	



BNPM/NCB/323/2025 -26 dated 29.10.2025	BANK NOTE PAPER MILL INDIA PRIVATE LIMITED	SHEET 7 OF 8
	TENDER FOR SUPPLY, INSTALLATION, TESTING, COMMISSIONING OF DYNAMIC VOLTAGE SAG CORRECTOR AT BNPM PLANT, MYSURU. CORRIGENDUM NO. 1	

Sl. No.	<u>Tender Clause</u>	<u>Pre-bid query</u>	<u>Existing tender terms</u>	<u>Amendment to the tender terms</u>
3	SCC, Sec V: Sr No. 4: Warranty & support	OEM meeting the criteria.	The System supplied shall remain under on-site warranty for a period of 1 Year from the date of completion of commissioning. This clause is to be read along with GCC clause 16. Note: OEM to ensure technical support & spares for the system to be supplied for a minimum period of five years after date of completion of successful commissioning.	The System supplied shall remain under on-site warranty of OEM for a period of 1 Year from the date of completion of commissioning. This clause is to be read along with GCC clause 16. Note: OEM to ensure technical support & spares for the system to be supplied for a minimum period of five years after date of completion of successful commissioning.



BNPM/NCB/323/2025 -26 dated 29.10.2025	BANK NOTE PAPER MILL INDIA PRIVATE LIMITED	SHEET 8 OF 8
	TENDER FOR SUPPLY, INSTALLATION, TESTING, COMMISSIONING OF DYNAMIC VOLTAGE SAG CORRECTOR AT BNPM PLANT, MYSURU. CORRIGENDUM NO. 1	

4. ADDITION TO THE TENDER TERMS:

<u>Sl. No.</u>	<u>Tender Clause</u>	<u>Pre-bid query</u>	<u>Existing tender terms</u>	<u>Amendment to the tender terms</u>
1	Sec VII, Technical Specification & Scope of Work	CT Installation for Sag Corrector Schneider recommends installing Three Current Transformers (CTs) in the PCC for monitoring and sensing purpose, which will provide more accurate performance data. Please advise and confirm your concurrence.	Scope of CT is not incorporated.	Bidder may consider CT installation for Sag Corrector in the PCC for monitoring and sensing purpose and to meet the desired performance. Supply, installation, cabling & commissioning pertaining to CT will be in the scope of bidder.

5. REVISION OF TENDER:

<u>Sl. No.</u>	<u>Tender Clause</u>	<u>Existing tender terms</u>	<u>Amendment to the tender terms</u>
1	Due date & time for bid submission and bid opening:	Due date & time of bid submission: 19.11.25, @ 11:00 hours. Tender opening due date & time: 19.11.25, @ 11:30 hours	Due date & time of bid submission: 26.11.25, @ 11:00 hours. Tender opening due date & time: 26.11.25, @ 11:30 hours

