

<b>BNPM/NCB/524/2024-25 dated 05.02.2025</b>	<b>BANK NOTE PAPER MILL INDIA PRIVATE LIMITED</b>	<b>SHEET 1 OF 3</b>
	TENDER FOR PROVIDING OPERATION & MAINTENANCE OF ELECTRICAL INSTALLATION SYSTEM AT BNPM PLANT, MYSURU  <b>CORRIGENDUM NO. 2</b>	

**CORRIGENDUM No.2, DATED 20.02.2025**

**FOR**

**TENDER NO. BNPM/NCB/524/2024-25 dated 05.02.2025**

**TENDER FOR PROVIDING OPERATION & MAINTENANCE OF ELECTRICAL INSTALLATION  
SYSTEM AT BNPM PLANT, MYSURU**



<b>BNPM/NCB/524/2024-25 dated 05.02.2025</b>	<b>BANK NOTE PAPER MILL INDIA PRIVATE LIMITED</b>	<b>SHEET 2 OF 3</b>
	TENDER FOR PROVIDING OPERATION & MAINTENANCE OF ELECTRICAL INSTALLATION SYSTEM AT BNPM PLANT, MYSURU	
	<b>CORRIGENDUM NO. 2</b>	

**1.0 SCOPE OF THIS CORRIGENDUM**

**1.1** This corrigendum dated 20.02.2025 is issued for clarification and addition of tender terms.

**1.2** Except for details mentioned herein, all other details contained in the tender no. BNPM/NCB/524/2024-25 dated 05.02.2025, & Corrigendum 1, dated 11.02.2025 shall remain applicable and unchanged.

**2.0 CLARIFICATION**

<b><u>Sl. No.</u></b>	<b><u>Tender clause</u></b>	<b><u>As per tender</u></b>
1	Sec VII, Technical Specification & Scope of Work, Clause 8: Annual Relay Testing	List of relays are attached as Annexure 1.

**RELAY DETAILS**

**Electromagnetic Relays**

<b>Sl No</b>	<b>Relay Description</b>	<b>Make</b>	<b>Unit</b>	<b>Quantity</b>
1	27 -Undervoltage protection relay	Alstom	Nos	1
2	59 - Over voltage protection relay		Nos	1
3	Circuit Breaker Trip Ckt supervision relay		Nos	6
4	86 - High speed tripping relay		Nos	3
5	Master trip Relay (Two Element)		Nos	2
6	Master trip Relay (Single Element)		Nos	31
7	80 AC- AC supply supervision relay		Nos	3
8	80 DC-DC supply supervision relay		Nos	3
9	Restricted earth fault relay		Nos	4
10	standby earth fault relay		Nos	4
11	Auxiliary relay for transformer fault		Nos	59
12	Instantaneous under voltage relay (VAGM)		Nos	8

BNPM/NCB/524/202 4-25 dated 05.02.2025	<b>BANK NOTE PAPER MILL INDIA PRIVATE LIMITED</b>	SHEET 3 OF 3
	TENDER FOR PROVIDING OPERATION & MAINTENANCE OF ELECTRICAL INSTALLATION SYSTEM AT BNPM PLANT, MYSURU	
	<b>CORRIGENDUM NO. 2</b>	

13	Standby earth fault relay		Nos	14
14	Instantaneous earth fault relay		Nos	13
15	Bus zone differential relay for zone-1		Nos	2
16	Under voltage relay timer (Definite Time Relay)		Nos	2
17	Pilot wire protection relay HORM4RF including Injection equipment and Supervision Equipment in both Incoming and Outgoing Panels		Nos	28
18	Directional IDMT L O/C Relay (67 R)	Alstom	Nos	2
19	Directional IDMT L O/C Relay (67 B)		Nos	2
20	Directional IDMT Earth Fault Relay (67 N)		Nos	2
21	Master trip relay (86)		Nos	2
22	Trip circuit Supervision relay (195)		Nos	2
23	Trip circuit Supervision relay (295)		Nos	2
24	AC Supervision Relay		Nos	2
25	DC Supervision Relay		Nos	2
26	Trip Supervision Relay (95/86)		Nos	2
		Total	202	

Numerical Relays				
Sl No	Relay Description	Make	Unit	Quantity
27	P141- Over current & Earth fault protection relay	Schneider Electric	Nos	1
28	Vamp 50 - Over current & Earth fault protection relay		Nos	33
29	P642 - Transformer Differential protection relay		Nos	2
30	Synchronisation Relay		Nos	1
31	VAMP -230 Feeder Protection relay		Nos	2
32	Distance Protection (87 L) Numerical Relay	ABB	Nos	4
Total			43	
Grand Total			245	