

BNPM/NCB/O&MEL/ 0710/2021-22 dated 24.03.2022	BANK NOTE PAPER MILL INDIA PRIVATE LIMITED	
	TENDER FOR OPERATION & MAINTENANCE OF ELECTRICAL INSTALLATION SYSTEM AT BNPMIPL, MYSURU CORRIGENDUM NO. 1	

CORRIGENDUM No. 1, DATED: 15.04.2022

FOR

TENDER NO. BNPM/NCB/O&MEL/0710/2021-22 dated
24.03.2022

**TENDER FOR PROVIDING OPERATION & MAINTENANCE SERVICES OF
ELECTRICAL INSTALLATION SYSTEM, BNPMIPL - MYSURU**



BNPM/NCB/O&MEL/ 0710/2021-22 dated 24.03.2022	BANK NOTE PAPER MILL INDIA PRIVATE LIMITED	
	TENDER FOR OPERATION & MAINTENANCE OF ELECTRICAL INSTALLATION SYSTEM AT BNPMIPL, MYSURU	
	CORRIGENDUM NO. 1	

1.0 SCOPE OF THIS CORRIGENDUM

- 1.1 This corrigendum dated 15.04.2022, is issued for amendment, clarification and extension of bid submission due date against the tender floated on 24.03.2022.
- 1.2 Except for details mentioned herein, all other details contained in the tender no. BNPM/NCB/O&MEL/0710/2021-22 dated 24.03.2022, shall remain applicable and unchanged.

2.0 AMENDMENT TO THE TENDER:-

<u>Sl. No.</u>	<u>Tender Clause No</u>	<u>Existing Provision</u>	<u>Action/Clarification incorporated in this Corrigendum</u>
1.	Sec IX, Qualification/Eligibility Criteria, Category; Experience & Past Performance	<p>Eligibility Criteria :</p> <p>Bidders firm should have provided at least one year services towards operation & maintenance of Electrical Installation system of similar type in last five (05) years for the period ending as on 28.02.2022.</p> <p>Services of similar type means – Operation and Maintenance of electrical installations of minimum 66KV/11KV Substation.</p>	<p>To be read as:</p> <p>Eligibility Criteria :</p> <p>Criteria (i):</p> <p>Bidders firm should have provided at least one year services towards operation & maintenance of Electrical Installation system of similar type in last five (05) years for the period ending as on 28.02.2022.</p> <p>Services of similar type means – Operation and Maintenance of electrical installations of minimum 66KV/11KV Substation.</p>



BNPM/NCB/O&MEL/ 0710/2021-22 dated 24.03.2022	BANK NOTE PAPER MILL INDIA PRIVATE LIMITED	
	TENDER FOR OPERATION & MAINTENANCE OF ELECTRICAL INSTALLATION SYSTEM AT BNPMIPL, MYSURU	
	CORRIGENDUM NO. 1	

		<p>Documents to be submitted</p> <p>a) Copy of Work order / Contract</p> <p>b) Documentary evidence towards successful completion of the above (Ref point a) Work order/ Contract</p> <p>c) PF, ESI Registration certificate</p>	<p>Documents to be submitted</p> <p>a) Copy of Work order / Contract</p> <p>b) Documentary evidence towards successful completion of the above (Ref point a) Work order/ Contract</p> <p>c) PF, ESI Registration certificate</p> <p>Criteria (ii):</p> <p>Bidder should possess valid Supergrade Electrical Contractor License.</p> <p>Documents to be submitted</p> <p>Valid Supergrade Electrical Contractor License.</p>
--	--	---	--



BNPM/NCB/O&MEL/ 0710/2021-22 dated 24.03.2022	BANK NOTE PAPER MILL INDIA PRIVATE LIMITED	
	TENDER FOR OPERATION & MAINTENANCE OF ELECTRICAL INSTALLATION SYSTEM AT BNPMIPL, MYSURU	
	CORRIGENDUM NO. 1	

B. CLARIFICATION TO THE TENDER:

<u>Sl. No.</u>	<u>Clarification sought by prospective bidder</u>	<u>Action/Clarification incorporated in this Corrigendum</u>
1.	Annual Relay Testing- Types of Relay & quantity may be provided	Relay details are enclosed herewith as Annexure-1
2.	Scope of providing tools & tackles	All tools & tackles shall be under the scope of BNPM

C. REVISION TO THE TENDER

<u>Sl. No.</u>	<u>Previous Provisions</u>	<u>Action/Clarification incorporated in this Corrigendum</u>
1.	Last date of Bid Submission is 15.04.2022 up to 1100 Hrs.	Last date of submission of bid is 26.04.2022 till 1100 Hrs. Tender opening date and time: 26.04.2022 at 1130 Hrs.



BNPM/NCB/O&MEL/ 0710/2021-22 dated 24.03.2022	BANK NOTE PAPER MILL INDIA PRIVATE LIMITED	
	TENDER FOR OPERATION & MAINTENANCE OF ELECTRICAL INSTALLATION SYSTEM AT BNPMIPL, MYSURU	
	CORRIGENDUM NO. 1	

Annexure-1: Types of Relay & Quantity

RELAY DETAILS					
Electromagnetic Relays					
SI No	Relay Description	Make	Model	UNIT	Installed Quantity
1	27 -Undervoltage protection relay	Alstom	VTUM21AFD21A	Nos	1
2	59 - Over voltage protection relay		VTU31AFBCH8001A	Nos	1
3	Circuit Breaker Trip Ckt supervision relay		VAX31ZG8074BCH	Nos	6
4	86 - High speed tripping relay		VAJHM23ZG0752BBA	Nos	3
5	Master trip Relay (two Element)		VAJH23ZG0750BBA	Nos	2
6	Master trip Relay (Single element)		VAJH13YF0751ABA	Nos	31
7	80 AC- AC supply supervision relay		VAA11YF7752CA	Nos	3
8	80 DC-DC supply supervision relay		VAA11YF8752CA	Nos	3
9	Restricted earth fault relay		CAG14AF12A	Nos	4
10	standby earth fault relay		CDG11AF006SACH	Nos	4
11	Auxilliary relay for transformer fault		VAA33ZG8323BCH	Nos	59
12	Instantaneous under voltage relay (VAGM)		VAGM22AF171G	Nos	8
13	Standby earth fault relay		CDG12AF302K	Nos	14
14	Instantaneous earth fault relay		CAG14AF8002ACH	Nos	13
15	Bus zone differetial relay for zone-1		VTX31AF8002ACH	Nos	2
16	Under voltage relay timer (Defnite Time Relay)		VTT11ZG8029LCH	Nos	2
17	Pilot wire protection relay HORM4RF including Injection equipment and Supervision Equipment in both Incoming and Outgoing Panels		HORM4RF7A , HORM4RF7B	Nos	28
Total					184
Numerical Relays					
SI No	Relay Description	Make	Model	UNIT	Installed Quantity
18	P141- Over current & Earth fault protection relay	Schneider Electric	P141316N6M0468J	Nos	1
19	Vamp 50 - Over current & Earth fault protection relay		VAMP 50	Nos	33
20	P642 - Transformer Differential protection relay		P642316A6M0A28J	Nos	2
21	Synchronisation Relay		VAMP 57/ V57F- 3AAA2BBA	Nos	1
22	VAMP -230 Feeder Protection relay		VAMP 230	Nos	2
Total					39
Grand Total					223

