BNPM/LTE/IM3/863/20	BANK NOTE PAPER MILL INDIA PRIVATE LIMITED	Cover Sheet	
	CORRIGENDUM No.: 1		
19-20	Supply of Induction Motor (3 Types) at BNPM Plant, Mysuru	Sheet 1 of 2	

CORRIGENDUM NO. 1 DATED 20.12.2019

FOR

TENDER No.

BNPM/LTE/IM3/863/2019-20 DATED 28.11.2019

FOR

Supply of Induction Motor (3 Types) at BNPM Plant, Mysuru

PURCHASER : BANK NOTE PAPER MILL INDIA PRIVATE LIMITED

EQUIPMENT : **INDUCTION MOTORS (3 TYPES)**

LOCATION : BNPM PLANT, MYSURU, KARNATAKA



BNPM/LTE/IM3/863/ 2019-20	BANK NOTE PAPER MILL INDIA PRIVATE LIMITED	Cover Sheet
	CORRIGENDUM No.: 1	
	Supply of Induction Motor (3 Types) at BNPM Plant, Mysuru	Sheet 2 of 2

1.0 SCOPE OF THIS CORRIGENDUM

- 1. Details provided in this corrigendum shall override those mentioned in the tender no. BNPM/LTE/IM3/863/2019-20 Dated: 28.11.2019
- 2. Except for details mentioned herein, all other details contained in the tender no. BNPM/LTE/IM3/863/2019-20 Dated: 28.11.2019 shall remain unchanged.

3. Due date of bid submission:

Closing date and time for receipt of tenders	03.01.2020; 1430 Hrs.
Time and date of opening of techno-commercial bid	03.01.2020; 1500 Hrs.

4. Inclusions/Clarifications through this corrigendum:

Sl. No.	As per Tender Clause	Action/Clarification incorporated in this Corrigendum
	Section VII: Tech	<u>nical</u>
	Specifications (Page no. 33 of	54}
	Bidder Queries: (a) For what Application the Market will be used	Motor (a) For Blower Application
1	(b) Is it a replacement for existing Motor if yes kindly prus the details of existing motors	Details are exactly same as per the
	(c) Method of Starting .i.e. Dire Line or VFD.	ct on (c) 30KW Induction Motor – DOL & VFD 45KW Induction Motor – VFD
	(d) Whether the connect equip is belt driven or direct coupled.	ment (d) 30KW Induction Motor – Directly coupled 45KW Induction Motor – Belt driven

