

**CORRIGENDUM No. 1 DATED 04.12.2024**

**FOR**

**TENDER No.**

**BNPM/OTE/369/2024-25 dated 15.11.2024**

**1.0 Details of Corrigendum as under**

Sl. No.	Tender clause	Existing	To be read as
1	Page No.37, Section VII - Technical Specifications, Point No. 2 & Page No.39, Section VIII - Quality Control Requirements, Point No. 3	<b>Process connection:</b> M30x1.5 Male with front flush/ M20 male with front flush along with M30*1.5 reducer for M20 male connector	As per Tender.
2	Page No.37, Section VII - Technical Specifications, Point No. 13 & Page No.39, Section VIII - Quality Control Requirements, Point No. 14	<b>Application</b> - for Level Measurement	<b>Application</b> - Pressure transmitter for Level Measurement
3	Page No.37, Section VII - Technical Specifications, Point No. 18 & Page No.39, Section VIII - Quality Control Requirements, Point No. 20	<b>Preferred Makes:</b> Vega / Klay / E&H/Yokogawa or any other substantially equivalent OEM approved by BNPM. Prior approval of BNPM before bid submission may be obtained for substantially equivalent product.	<b>Preferred Makes:</b> Vega / Klay / E&H/Yokogawa/ Aplisens/ Honeywell or any other substantially equivalent OEM approved by BNPM. Prior approval of BNPM before bid submission may be obtained for substantially equivalent product.
<b>Amendment</b>			
4	Page No.37, Section VII - Technical Specifications, Point No. 14 & Page No.39, Section VIII - Quality Control Requirements, Point No. 15	<b>Media</b> - Viscous fluids	<b>Media</b> - Comber Pulp with viscosity range 15-30 mPa (millipascal) seconds and water



**Corrigendum -1: e-Tender for Supply of Pressure Transmitter at BNPM,  
Mysore**

**(Tender No: BNPM/OTE/369/2024-25 dated 15.11.2024)**

Sl. No.	Tender clause	Existing	To be read as
<b>Addition</b>			
5	<b>Under Section VII - Technical Specifications</b>	NIL	<b>S.No: 19 (NEW)</b>  <b>Tank Height in Meters:</b>  Tanks with different height ranging from 1 meter to 4 meter.

**2.0 PROPOSED EXTENSION FOR BID SUBMISSION DUE DATE**

SNo.	Tender clause	Existing	Extended upto
1	NIT, Sec I	Due date & time of bid submission: 06.12.2024, @ 1100Hrs.  Tender opening due date & time: 06.12.2024 @ 1130 Hrs.	Due date & time of bid submission: 11.12.2024, @ 1100Hrs.  Tender opening due date & time: 11.12.2024 @ 1130 Hrs.

**EXCEPT FOR DETAILS MENTIONED HEREIN, ALL OTHER DETAILS CONTAINED IN THE TENDER NO. BNPM/OTE/369/2024-25, dated: 15.11.2024, SHALL REMAIN APPLICABLE AND UNCHANGED.**

