BNPM/OTE/ 3/2024-25

BANK NOTE PAPER MILL INDIA PRIVATE LIMITED

TENDER FOR SUPPLY, INSTALLATION, TESTING & COMMISSIONING OF CHILLER CABLE BOX AT BNPM PLANT, MYSURU

CORRIGENDUM NO.1

CORRIGENDUM No.1, DATED 16.04.2024

<u>FOR</u>

TENDER NO. BNPM/OTE/3/2024-25 dated 04.04.2024

TENDER FOR SUPPLY, INSTALLATION, TESTING & COMMISSIONING OF CHILLER CABLE BOX AT BNPM PLANT, MYSURU

1.0 SCOPE OF THIS CORRIGENDUM

Technical Specification & Scope of Work is read as:

<u>Sl.</u>	Previous Provision	Action/Clarification incorporated in this
<u>No.</u>		corrigendum
	Technical Specification & Scope of	Technical Specification & Scope of
	Work	Work
1.	The above work includes the following.	1) The Junction shall be suitable for
	Supply, Installation, Testing & Commissioning of Chiller Cable Box for	a. Termination of incoming cable 300 sq.mm 3.5 core Aluminium XLPE armoured -2 runs
	1) Incoming Cable 300 sq. mm 3.5 core Aluminium	 b. Termination of outgoing cable 240 sq. mm 3.5 core Copper XLPE armoured – 1 run
	2) Outgoing Copper Cable shall be suitable for 630A Three pole 36kA MCCB	c. The mounting provision has to be made to fix the MCCB Model:



BANK NOTE PAPER MILL INDIA PRIVATE LIMITED **TENDER FOR SUPPLY, INSTALLATION, TESTING & COMMISSIONING OF BNPM/OTE/** 3/2024-25 **CHILLER CABLE BOX AT BNPM PLANT, MYSURU CORRIGENDUM NO.1** MCCB PR221DS. make: ABB (reference 3) Existing Model :PR221DS,Make : ABB dimensional drawing is attached) 4) With indication R,Y,B Lamp-2) The junction box shall be 230 V ,Control MCB 6A supplied with indication lamp for Single Pole and wiring R, Y, B (230 V AC), Control MCB accessories – 3 sets 6A Single Pole and wiring accessories - 3 sets 5) CRCA Sheet Steel 3) Enclosure shall be CRCA Sheet Steel 6) Enclosure: IP42 4) Protection of enclosure: IP42 7) Approximate Dimension : H-1000 mm, W -500 mm, D-5) Approximate Dimension: H-1000 350 mm mm, W -500 mm, D- 350 mm Overall scope of work shall be only supply of junction box complaining above specifications/conditions. Installation & commissioning shall be in the scope of BNPM.

EXCEPT FOR DETAILS MENTIONED HEREIN, ALL OTHER DETAILS CONTAINED IN THE TENDER NO. BNPM/OTE/3/2024-25, dated 04.04.2024, SHALL REMAIN SAME AND UNCHANGED.

