

BNPM/LTE/PR. Transmitter/605/20 18-19	BANK NOTE PAPER MILL PRIVATE LIMITED	
	CORRIGENDUM NO. 2	

**CORRIGENDUM No. 2, DATED 20.11.2018**

**FOR**

**e-Tender No. BNPM/LTE/PR. TRANSMITTER/605/2018-19 Dated  
30.10.2018**

**Enquiry for Supply of PR. Transmitter**

**Client: BANK NOTE PAPER MILL INDIA PRIVATE LIMITED, MYSURU,  
KARNATAKA**



**Administrative Office Building,  
Entry Gate-1, Paper Mill Compound,  
Note Mudran Nagar,  
Mysuru-570003**



**1.0 SCOPE OF THIS CORRIGENDUM:**

a. Following technical clarification is being incorporated:

<b><u>Sl No.</u></b>	<b><u>Clause</u></b>	<b><u>Previous Provisions</u></b>	<b><u>Action/Clarification incorporated in this Corrigendum</u></b>
<b>1.</b>	Under Section VII- Technical Specifications	Technical Detail of Application & Measuring Medium was not incorporated in Technical Specifications	Under Section VII – Technical Specifications, Clause No.10, i.)APPLICATION - Hydrostatic Level Measurement in Process Tanks ii.) MEASURING MEDIUM - Cotton based pulp / Water are being incorporated against Pressure Transmitter (0-0.4 Bar) & Pressure Transmitter (0-0.2 Bar)

EXCEPT FOR DETAILS MENTIONED HEREIN, ALL OTHER DETAILS CONTAINED IN **LIMITED TENDER ENQUIRY NO. BNPM/LTE/ PR. Transmitter /605/2018-19 & CORRIGENDUM 1** SHALL REMAIN APPLICABLE AND UNCHANGED.

