

Issuing Date: 03.08.2018 12:00 hrs. Closing date: 23.08.2018 15:00 hrs.

## 1. Scope of work:

Supply of Panel Mounted Universal Input Process Indicator as per technical specifications.

## 2. Terms & Conditions:

S. No	Particulars	Quantity			
1.	Payment Terms	100% on receipt and acceptance of goods by the consignee at destination and on production of all required documents by th supplier.			
2.	Price	Price should be inclusive of all taxes & duties.			
3.	Freight	Shall be included in quoted price.			
4.	Packing & Forwarding	Shall be included in quoted price.			
5.	Delivery Terms	D.A.P, Bank Note Paper Mill India Private Limited, Mysore			
6.	Warranty Period	from date of supply at BNPM, Mysuru			
7.	Warranty Certificate	Applicable / Not Applicable			
8.	Delivery Period	2 weeks from date of receipt of purchase order			
9.	Material to be delivered at	Engineering Stores, Bank Note Paper Mill India Private Limited, Note Mudran Nagar, Mysore 570 003.			
10.	Contact person	Mr. Gopalakrishnan M P: 0821-2401158			

## **Technical Specifications:**

S No	Particulars	Specifications/BNPM Requirement	Bidder offered specifications	Deviations (if any)		
1	Material	Universal Input Process Indicator				
2	Туре	Microprocessor / Microcontroller based				
3	Configuration/Programming	Through Front Facia Keys				
4	Input Type	Universal inputs (4-20 mA DC CURRENT, mV, RTD (Pt-100, Pt-1000) Thermocouple, 1-5V DC etc, (configurable)				
5	Transmitter Power Supply	24V DC @ 30 mA or Better				
6	Display	5-digit, 0.8"(20.3mm) Height, LED/TFT Display				
7	Decimal Point Position	Configurable				
8	Accuracy	+/- 1% of FSD				
9	Relay Output	2 SPDT Relay (2NO+2NC) required (Configurable High/Low Alarms) + Display LED's				
10	Relay Ratings	230 V AC, 5A (Resistive)				



11	Enclosure Material	Metallic/PC/ABS	
12	Ingress Protection Class	IP65 for front facia or better	
13	Power Supply	10 – 30 V DC	
14	Dimensions	Front: 48mm(H) x 96mm(W) x 65mm /STD (D)Panel Cut Out: 45mm(H) x 92mm (W)	
15	Mounting Accessories	Required for Panel Mounting	
16	User Manual	01 set required	
17	Diagnostic Messages	Process overflow, Process underflow and Sensor break	
18	Ambient Temperature	0 - 55°C	
19	Relative Humidity	Up to 95% Non-condensing	
20	Make:	Multispan, Masibus, Phoenix Contacts, Yokogawa, M-Systems, ABB, SiemensImage: Contact of the second se	

#### Note:

1. The bidder has to quote technical parameters in the above format only, clearly indicating the deviations (if any).

2. All suggestions/recommendations should be accompanied by drawings/catalogues/manuals mandatorily.

3. Traceable Test Certificate and Warranty Certificate should be supplied.

(To be signed & stamped and submitted along with Price Bid).



#### **Price Bid Format :**

S No	Description	Qty	UOM	Unit rate	Freight, P&F Charges	GST @ 18% (HSN - 8473)	Unit rate including GST & Freight, P&F Charges	Grand total inclusive of GST and Freight, P&F Charges (D.A.P, BNPM, Mysore)
1	Supply of Panel Mounted Universal Input Process Indicator as per technical specifications	5	Nos					
	Total price inclusive of all tax, freight , P&F charges							

## HSN Codes: (8473)

We hereby confirm that

- 1. We accept all terms & conditions mentioned in the enquiry.
- 2. Price quoted is inclusive of all taxes, P&F, freight etc. on D.A.P, BNPM, Mysore basis.

Signature of bidder:....

Name of the Firm:....

Seal of the firm: .....

GST No: .....

