



ಬೆಂಗಳೂರು ವಿಶ್ವವಿದ್ಯಾನಿಲಯ

## TEST REPORT

**Address of the Customer:**

M/s.Bank Note Paper Mill India Pvt.Ltd.  
Note Mudran Nagar  
Mysore- 570 003.

**Report No.** WWD/2018/05/0505  
**Date of Receipt** 24/05/2018  
**Date of Analysis** 24/05/2018  
**Date of Completion** 30/05/2018  
**Date of Report** 30/05/2018  
**Job Order No.** WWD/2018/05/0505  
**Sampling Type** Grab  
**Sampling Point** After Filtration Tank  
**Your Reference** Verbal

**Sample Particulars** ETP Treated water  
**Date of Sampling** 24/05/2018  
**Sample Qty.** 2Ltrs  
**Sample Marked** N.S

**Sample Description :** Colourless liquid having unobjectionable odor.

Sl. No.	Tests	Unit	Result	Tolerance Limits	Method of Test
<b>Chemical Test</b>					
1	Colour	Hazen units	<5.0(BDL)	See Note	IS3025(Part-4):1983
2	Odor	----	Unobjectionable	See Note	IS3025(Part-5):1983
3	Total Suspended Solids	mg/L	2.0	100 max	IS3025(Part-17):1996(Reaff:2012)
4	pH Value	----	7.9	6.5-8.0	IS3025(Part-11):1983(Reaff:2012)
5	Oil & Grease	mg/L	<1.0(BDL)	10 max	IS3025(Part-39):1991(Reaff:2009)
6	Biochemical Oxygen Demand,5 Days@20°C	mg/L	3.0	30 max	IS3025(Part-44):1993(Reaff:2009)
7	Chemical Oxygen Demand as O2	mg/L	9.0	250 max	IS3025(Part-58):2006(Reaff:2012)

**Note:**

- 1)Sample preserved@2-8°C,2)N.S:Not Specified,3)BDL:Below Detection Limit.
- 4)All efforts should be made to remove color and unpleasant odor as far as practicable.

  
Tested by

  
Authorised Signatory